

UGAM CHEMICALS

COMPANY	: M/s APOLLO TYRES LTD., VADODARA.
PROBLEM REPORTED	: Very high shop floor temperature providing Non-comfortable atmosphere for workers.
PROPOSED SOLUTION	: UGAM INSULMIX SYSTEM for roof to be applied to rooftop from exterior.
OBSERVATIONS BEFORE APPLICATION	: Roof temp of Cement sheets from interior were observed to be 70 degrees C. and room temperature was 45 on average.
OBSERVATION AFTER APPLICATION	: Roof temp of Cement sheets from interior has come down to 39 degrees C and room temp also was 39 deg C on average.
RESULTS ACHIEVED	: Shop floor Temperature was reduced by 6 degrees C.



**30, ADITYA RESIDENCY, MITRAMANDAL CHOWK, 498, PARVATI, PUNE,
MAHARASHTRA, INDIA, TEL- 08669922233 / 08669922244.**

Fax- 020 24434075, e-mail- ugamchem@hotmail.com